



NOTE

1. MAIN PIPE IS OF 40 mm DIA AND SMALLER BEING 25 mm DIA ALL 'B' CLASS G1 PIPE
2. A MINIMUM OF 2 CLAMPS MADE OUT OF 50 mm WIDE AND 5 mm TH WITH 10 mm DIA BOLT & NUT TO BE USED FOR FIXING
3. CLAMP SHOULD BE PAINTED WITH TWO COATS IN EACH OF PRIMER ZINC CHROMATE AND ALUMINIUM PAINTS
4. SAMPLE SHALL BE GET APPROVED BY THE ENGINEER-IN-CHARGE BEFORE MANUFACTURED IN BULK
5. ALL DIMENSIONS ARE IN mm UNLESS STATED OTHER WISE
6. COUPLING MARKED AS Ⓞ SHOULD BE TO SUIT 40 mm DIA G1 PIPE FOR FIXING OF FITTING OTHER THAN W/T FLUORESCENT

SOUTHERN RAILWAY	
TITLE: BRACKET FOR MOUNTING OF WATER -TIGHT FLOURESCENT FITTINGS AND ALL OTHER STREET LIGHT TYPE FITTINGS	
Dwg. No.	CEE/CN/MS/03-2004
DESIGNED BY A. Natarajan	CEE/CN/MDC XEE/CN/ERS XEE/CN/MDU
DY. CEE/G/CN/MS	
CEE/CN/MS	